



Evaluation Listing CCMC 13008-L

MASTERFORMAT: 07 46 33.01
Issued: 2001-02-08
Re-evaluated: 2009-11-16
Re-evaluation due: 2013-02-08

CertainTeed Vinyl Siding

1. Evaluation

Conforms to CAN/CGSB-41.24-95, "Rigid Vinyl Siding, Soffits and Fascia."

2. Description

A single-wall, interlocking, exterior cladding system made of polyvinyl chloride for use in wall and soffit applications. The product has a nominal thickness of 1.0 mm. The product is available in single, double, double cove, and triple horizontal profiles in widths of 76, 100, 114, 127, 165, and 203 mm. Also available are single 159-mm or 203-mm, double 127-mm, and triple 100-mm vertical profiles as well as 104, 127, and 203-mm perforated, full vent and centre vent soffit profiles.

3. Standard and Regulatory Information

See the Preface and the standard for explanation.

Listing Holder: CertainTeed Corporation
803 Belden Road
Jackson, MI 49203
U.S.A.
Tel: 517-780-3185
Fax: 517-780-3156

Plant(s): Jackson, MI, U.S.A.
Williamsport, MD, U.S.A.
Claremont, NC, U.S.A.

This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://www.nrc-cnrc.gc.ca/eng/services/irc/ccmc.html>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.