

Certificate of Compliance

Certificate Number **020909-R684C**
Report Reference **R684, April 27, 1971**
Issue Date **2009-02-09**

Page 1 of 1



Issued to: **Certainteed Corp**
Blue Bell, PA 19422

*This is to certify that
representative samples of*

Prepared Roof Covering Materials

Class A Fire Resistant, Asphalt Glass Fiber Mat Shingles, designated: CT20,
Firescreen or Firehalt.

*Have been investigated by Underwriters Laboratories Inc.® in accordance
with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:


CAN/ULC S107-M87, Standard Methods of Fire Tests of Roof Coverings;
CAN/CSA A123.5-98, Asphalt Shingles Made from Glass Felt and Surfaced with
Mineral Granules (wind resistance); ASTM D3018, Class A Asphalt Shingles
Surfaced with Mineral Granules.

Additional Information:

These products are manufactured by CertainTeed or by GS Roofing Products, Inc.
d/b/a CertainTeed.

These shingles are composed of a glass fiber mat impregnated and coated with
asphalt, surfaced with mineral granules.

**Only those products bearing the UL Listing Mark should be considered
as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol
UL in a circle:  with the word "LISTED"; a control number (may be
alphanumeric) assigned by UL; and the product category name (product
identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *William G. Marshall*
William G Marshall
Underwriters Laboratories Inc.

Reviewed by: *Alpesh Patel*
Alpesh Patel
Underwriters Laboratories Inc.