



Evaluation Listing

CCMC 13020-L

MASTERFORMAT

Issued	07 21 13.02
Re-evaluated	2001-06-05
Revised	2007-07-18
Re-evaluation due	2008-05-01
	2010-06-05

Thermal Fiber Glass Batt and Roll Insulation

1. Evaluation

Conforms to CAN/ULC-S702-97, “Mineral Fibre Thermal Insulation for Buildings,” Type 1. The design thermal resistance values are as indicated in the following Table. Thicknesses listed are for batts, except for 67 mm and 98 mm, which are for rolls only. The products are manufactured at the following plants and are referenced adjacent to the design thicknesses in the Table that follows:

- (1) Kansas City, Kansas;
- (2) Mountaintop, Pennsylvania;
- (3) Athens, Georgia; and
- (4) Chowchilla, California.

Design Thickness (mm)	Design RSI (m ² ·KW ⁻¹)
67 ⁽³⁾	1.4
64 ⁽⁴⁾	1.4
89 ⁽⁴⁾	1.8
89 ⁽¹⁾⁽²⁾⁽³⁾⁽⁴⁾	2.1
89 ⁽¹⁾⁽²⁾⁽³⁾	2.3
89 ⁽¹⁾⁽³⁾⁽⁴⁾	2.4
98 ⁽³⁾	2.1
140 ⁽²⁾⁽³⁾	3.9
152 ⁽¹⁾⁽²⁾⁽³⁾⁽⁴⁾	3.5
152 ⁽³⁾	4.2
216 ⁽¹⁾⁽²⁾⁽³⁾	4.9
241 ⁽¹⁾⁽³⁾	5.4
241 ⁽²⁾	5.5
267 ⁽¹⁾	6.1
286 ⁽¹⁾⁽⁴⁾	7.0

2. Description

A Type 1, mineral-fibre, thermal building insulation, manufactured as friction-fit batts and rolls.

3. Standard and Regulatory Information

See the Preface or the Standard for further explanation.

Listing Holder CertainTeed Corporation
 750 East Swedesford Road
 Valley Forge, Pennsylvania
 USA 19482-0105

Tel.: (800) 233-8990 Fax: (610) 341-7571

This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://irc.nrc.gc.ca/ccmc>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.