



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

CertainTeed Corporation
20 Moores Road
Malvern, PA 19355

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: : **CertainTeed Corporation's Coatings and Cements**

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.


RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of the NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No.16-0802.02 and consists of pages 1 through 5.

The submitted documentation was reviewed by *Freddy Semino* 



NOA No.: 19-0416.02
Expiration Date:09/13/21
Approval Date: 08/15/19
Page 1 of 5

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cements and Coatings
Materials: Asphalt

SCOPE:

This approves CertainTeed Corporation's Coatings and Cements, for use on existing roof assemblies, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriter Laboratories, Inc.	KAR-036-02-01	ASTM D 4586	02/09/12
PRI Construction Materials Technologies	KAR-046-02-01	ASTM D 1227	02/15/12
	KAR-052-02-01	ASTM D 3019	02/15/12
	KAR-055-02-01	ASTM D 2824	04/18/12
	KAR-072-02-01	ASTM D 41	05/28/13
	KAR-076-02-01	ASTM D 5895	11/06/13
	KAR-077-02-01	ASTM D 2824	08/21/14

MANUFACTURING LOCATIONS:

1. Clark, NJ.
2. Ft. Lauderdale, FL

INSTALLATION:

CertainTeed Corporation's Cements and Coating shall be applied in accordance with manufacturer's Product Data Sheet. For use in roof system approvals, refer to the specific Roofing System's, Product Control Notice of Acceptance for the proper application specifications.



NOA No.: 19-0416.02
Expiration Date: 09/13/21
Approval Date: 08/15/19
Page 2 of 5

PHYSICAL PROPERTIES OF COMPONENTS

Tradename: FlintPatch (Wet/Dry)
Application Rate: This material is applied by towel spread to an average thickness of 1/8", approximately 8 gal./sq.
Specifications: ASTM D D 4586 type I
Description: An asbestos free, general purpose flashing cement for repairing leaks in shingles, concrete, metal or asphalt roofs.
Container Size: 1, 3, 5 gallons and 10.3 oz. tube. Notice all precautions on container.
Manufacturing Location #2

Tradename: FlintBond Brush
Application Rate: This material is applied by brush at an approximate rate of 1 gal./100sq.ft. On porous or irregular surfaces, consult manufacturer for application rates.
Specifications: ASTM D3019 type III
Description: A cold applied, SBS polymer modified asphalt adhesive. Used to adhere SBS modified bitumen membranes, base and ply sheets, BUR ply sheets or fully granulated cap sheets.
Container Size: 5, 55, and 275 gallons. Note all precautions on container.
Manufacturing Location #2

Tradename: FlintBond Caulk and FlintBond Trowel
Application Rate: This material is applied by towel at an approximate rate of 1 gal./100sq.ft. On porous or irregular surfaces, consult manufacturer for application rates.
Specifications: ASTM D3019 type III
Description: A cold applied, SBS polymer modified asphalt adhesive. Used to make repairs on existing modified applications and flashings on vertical surfaces.
Container Size: 5 gallons. Note all precautions on container.
Manufacturing Location #2

Tradename: FlintPrime
Application Rate: Applied by brush or spray at an approximate rate of 1 to 2 gal/100sq. ft.
Specifications: ASTM D-41
Description: A general purpose asphalt primer. For use in the preparation of all types of surfaces previous to the application of hot or cold asphalt coatings. Used to coat all types of flat asphalt roof surfaces and to dampproof concrete, concrete block and masonry surfaces.
Container Size: 5, 55 and 275 gallons and 14 oz. spray can. Notice all precautions on container.
Manufacturing Location #1



Tradename: FlintCoat-E
Application Rate: Apply by brush or spray at an approximate rate of 4 gal/100sq.ft.
Specifications: ASTM D 1227 type II Class I
Description: An asbestos free emulsion roof coating manufactured with refined asphalt, bentonite clay, emulsifiers and fibers.
Container Size: 5, 55, and 275 gallons. Note all precautions on container.

Manufacturing Location #1

Tradename: FlintPrime SA
Application Rate: Apply by brush, roller, or hand sprayer at a rate of 1 gal/500sq.ft.
Specifications: ASTM D 41
Description: A waterbase polymer modified primer for self-adhering membranes. Suitable for use over asphalt, wood, plywood, gypsum board, insulation, and concrete surfaces.
Container Size: 1 and 5 gallon pails.

Manufacturing Location #1

Tradename: FlintCoat-A300
Application Rate: Apply by brush, roller, or spray at an approximate rate of 1 to 1-1/2 gal/100sq.ft.
Specifications: ASTM D 2824 Type III
Description: An asbestos free fibrated aluminum roof coating consisting of asphalts, pigment flakes of aluminum, solvents, and reinforcing fibers. For use on modified bitumen membranes, metal corrugated sdecks, and steep asphalt which has aged fro 180 days.
Container Size: 5, and 55 gallons. Note all precautions on container.

Manufacturing Location #1



LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this products.
2. CertainTeed Corporation’s Coatings and Cements shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test result shall be made available to Miami-Dade Product Control upon request.
5. Change in materials, use or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
6. These roof coatings shall not be applied over, prepared roofing; i.e., fibercement shingles, quarry slate, cement or clay roof tile, metal shingles, wood shingles or shakes.
7. CertainTeed Corporation’s Cements and Coatings shall be used as components within approved roofing systems in accordance with applicable building code. CertainTeed Corporation’s Coatings and Cements are not approved to be used as repair or recover roof systems.
8. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below



9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

