


# APP-IN-4-T



**Base sheet mechanically attached through insulated substrate, two adhered interply sheets and torch-welded APP modified cap**

## SUBSTRATE:

- Steel (Sec. 3.5)
- Wood (Sec. 3.10-3.11)
- Poured Gypsum (Sec. 3.12)
- Wood Fiber (Sec. 3.13)
- Insulation (Sec. 4.0)
- Re-cover (Sec. 5.0)

## MAXIMUM SLOPE:

Up to 6" : 12" (Sec. 15.3)

## ROOF ASSEMBLY:

One or more layers of approved insulation and/or coverboard:

- Insulation pre-secured with mechanical attachment.

Approved base sheet mechanically attached with approved screws and plates (Sec. 15.4.2).

Two approved interply sheets set in hot asphalt (Sec. 7.0), torch-welded (Sec. 8.0) or self-adhered (Sec. 10.2).

Approved cap sheet, torch-welded (Sec. 8.0).

## SUMMARY OF MATERIALS:

- One or more layers of Insulation and/ or coverboard
- Base sheet (1 ply)
- Interply sheet (2 ply)
- Cap sheet (1 ply)
- ASTM D 312 asphalt (2 moppings) (no moppings if interply torch-welded or self-adhered)

WARRANTY DURATIONS FOR THIS SPECIFICATION VARY BASED ON ROLL MATERIAL SELECTION; SEE WARRANTY MATRIX.

Applicable local building code may require more stringent installation requirements such as, but not limited to, increased fastener or adhesive densities to meet required wind uplift pressures. Consult local building code and uplift requirements prior to any application of CertainTeed roofing materials. CertainTeed is not responsible for failure to install roofing products per applicable local building codes.

## APPROVED BASE SHEETS:

(one of the following)

- All Weather/Empire® Base Sheet
- Flintlastic APP Base T
- Flintlastic Base 20
- Flintlastic Poly SMS
- Flintlastic Ultra Poly SMS
- Glasbase™ Base Sheet
- Yosemite® Venting Base Sheet

## APPROVED INTERPLY SHEETS:

(Two of the following)

### Hot Asphalt Applied

- All Weather/Empire Base Sheet
- Flintglas Ply 4
- Flintglas Premium Ply 6
- Flintlastic Base 20
- Flintlastic Poly SMS
- Flintlastic Ultra Poly SMS
- Glasbase Base Sheet
- Yosemite Venting Base Sheet

### Torch Welded

- Flintlastic APP Base T
- Flintlastic STA
- Flintlastic STA Plus
- Flintlastic Ultra Poly SMS

### Self-Adhered

- Black Diamond Base Sheet\*\*
- Flintlastic Ultra Glass SA\*\*

## APPROVED CAP SHEETS:

(one of the following)

- Flintlastic GTA\*
- Flintlastic GTA-FR\*
- Flintlastic STA
- Flintlastic STA Plus

## FINAL SURFACING:

For optional surfacing see Section 14.0.

Flintlastic STA and STA Plus (used as cap sheets) require reflective coating.

- FlintCoat A-300 or W (required over Flintlastic STA and STA Plus)

## FLASHING ASSEMBLY:

- **Standard.** Over a base sheet or bonded to a primed substrate. One ply Flintlastic modified cap sheet, per CT detail.
- **Premium.** Over a base sheet or bonded to a primed substrate. One smooth and one granulated modified membrane flashing, per CT detail.
- **Premium Alternate.** Over a base sheet or bonded to a primed substrate. One smooth modified membrane and CT SmartFlash®, per CT detail.

**Cants:** In angles of roof deck and vertical surfaces, the roofing contractor shall furnish and install an approved cant strip with a minimum 3" face.

\* Available with CoolStar® reflective granules

\*\* Not approved over Flintlastic APP Base T, Flintlastic STA or Flintlastic STA Plus

Consult CertainTeed General Recommendations for noted section references.

**CertainTeed**  
SAINT-GOBAIN