



Note:

1. This detail is appropriate for hot-asphalt, torch-welded, and cold process applications. For self-adhered systems, adapt modifications addressed in Section 5 of Construction Details.
2. See flashing specs in Appendix I.
3. General Contractor shall furnish and install minimum $\frac{1}{2}$ " thickness plywood continuous backing to height as detailed.
4. Nail top edge of base flashing 9" o.c. through tin-discs.

CertainTeed
SAINT-GOBAIN

Commercial Roofing

ISSUE DATE 8/30/2013	REVISION B	DRAWING NUMBER CT-08
SCALE Not To Scale		Sheet 1 of 1